



BID BULLETIN NO. 1
06 June 2022

Agency Reference No.: EMB-NCB-GOODS-02-2021

**Assessment, Supply, Delivery and Installation of Thirteen (13) Sets of Brand-New Preliminary
Disinfection and Storage Facilities for Collected Covid-19 Related Wastes**

Issued pursuant to Sec. 22.5 of the IRR of R.A. 9184 to clarify and/or amend certain provisions in the Bidding Documents issued for this project, considering the issues raised during the Pre-bid Conference held on 06 June 2022.

A. AMENDMENTS / INCLUSIONS

ITEM NO.	REFERENCE	BASIS FOR AMENDMENT/ INCLUSION
1	Section VII. Technical Specifications Page 30 20-footer container <ul style="list-style-type: none">- Thickness (panel): 1.905mm- Frame, pillars and rails: 4.7498mm- Either corrugated or non-corrugated sheet steel panel<ul style="list-style-type: none">➤ corrugated sheet steel panel - (minimum 14 guage 2 mm)➤ non-corrugated sheet steel panel - (minimum 12 guage 2.6 mm) Perimeter Fence <ul style="list-style-type: none">- concrete post and foundation, hog wire with GI pipes (frames and railings: 4 inches) with access/gate	To include the technical specifications of 20-footer container and Perimeter Fence
2	Section VII. Technical Specifications Page 35 Terms of Reference B. Certificate of Performance Evaluation from the SLCC client that the products similar to the item to be bid have performed very satisfactorily in service within the past five (5) years. <ul style="list-style-type: none">➤ Whether the project is similar or not similar in nature but related to waste management equipment and to submit a certification from the end-user for a very satisfactory performance or service.	To include the SLCC description of the project


3	Section VII. Technical Specifications Page 35 Terms of Reference Other Requirements during Post-qualification D. Present actual 20-footer container and 1 yellow bin	To include additional post-qualification requirement

B. CLARIFICATIONS

ITEM NO.	ISSUE / REQUEST	CLARIFICATION / RESOLUTION
1	<u>Mr. Benjie Mutia of C&G Environmental Management Corp.</u> asked if the 20-footer container is prefabricated or can be fabricated.	The BAC and end-user responded that since it is not stated in the Terms of Reference (TOR) the answer is both, the container can be either prefabricated or fabricated.

By rules all other portions of the Bidding Documents correspondingly affected by these amendments are likewise deemed amended to conform to this Bid Bulletin.

Amendments / inclusions made herein shall be considered an integral part of Bidding Documents.


JOSEPHINE B. GRAVOSO
BAC Chairperson

Received by the Bidder:

Date: _____